



DEVELOPMENT SERVICES DEPARTMENT – BUILDING SERVICES RESIDENTIAL OVERHEAD OR UNDERGROUND SERVICE CHANGE

Rev: 2 | Revision Date: 1/8/2025 | Print Date: 1/8/2025 I.D. Number: ROUSC

RESIDENTIAL OVERHEAD OR UNDERGROUND SERVICE CHANGE

JOB ADDRESS _____

CONTRACTOR OR OWNER _____

TYPE OF SERVICE:

_____ UNDERGROUND

_____ OVER \HEAD

ALL CONDUCTORS SIZED PER NEC ARTICLE 220

*ALL UNDERGROUND SERVICE CONDUCTORS MUST HAVE A WARNING RIBBON 12”
ABOVE CONDUIT 300.5 (D) (3)*



DEVELOPMENT SERVICES DEPARTMENT – BUILDING SERVICES

RESIDENTIAL OVERHEAD OR UNDERGROUND SERVICE CHANGE

Rev: 2 | Revision Date: 1/8/2025 | Print Date: 1/8/2025 I.D. Number: ROUSC

SERVICE ENTRANCE CONDUIT AND WIRE SIZE CU OR ALUMINIUM

